



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010307926715

NAME AND ADDRESS OF THE APPLICANT

Delixi (Wuhu) Network Technology Co., Ltd.
Xinwu Economic Development Zone, Wuhu County, Anhui Province(In DELIXI ELECTRIC(WUHU) LTD)

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, China 325604

NAME AND ADDRESS OF THE FACTORY

DELIXI ELECTRIC LTD (V010114)
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, China 325604

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-Breaker
CDL6i; Un:AC230V(2P),AC400V(4P);In:80A,100A;IΔn:30mA,100mA,300mA;Rated Residual Operating Type:Type AC,TypeA;Electromagnetic;Im:800A(In:80A),1000A(In:100A);IΔm:800A(In:80A),1000A(In=100A);Inc=IΔc:6kA;Poles:2P,4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 16916.1-2014;GB/T 16916.21-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Jul.09,2020

Valid until: Apr.14,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.27,2020

President:

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>