产品认证证书

证书编号：CQC2016010302876590

申请人名称及地址

德力西集团有限公司

浙江省乐清市柳市镇柳青路1号(德力西大厦)

制造商名称及地址

德力西集团有限公司

浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产企业名称及地址

德力西集团有限公司(V025650)

浙江省乐清市柳市镇大桥路165号

产品名称和系列、规格、型号

条形熔断器式隔离开关

CDHR16-160,CDHR16-160L； Uimp:6kV; Ui:800V; Ith:160A; Ue: AC500V/690V; Ie:160A; Iq:100kA(AC500V),50kA(AC690V)； 适用类别:AC-22B; 极数: 3P; 防护等级:IP20.

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合CQC11-462141-2019认证规则的要求，特发此证。

发证日期：2020年09月02日　　有效期至：2021年06月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：

中国质量认证中心

中国 . 北京 . 南四环西路188号9区 100070

http://www.cqc.com.cn

C 0357207

PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010302876590

NAME AND ADDRESS OF THE APPLICANT

DELIXI Group Co., Ltd.

(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI Group Co., Ltd.

(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

DELIXI Group Co., Ltd. (V025650)

No.165 Daqiao Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-Switch-Disconnector

CDHR16-160,CDHR16-160L ; Uimp:6kV; Ui:800V; Ith:160A; Ue: AC500V/690V; Ie:160A; Iq:100kA(AC500V),50kA(AC690V); Utilization Category:AC-22B; Poles: 3P; IP20.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Sep.02,2020 **Valid until:** Jun.21,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China

http://www.cqc.com.cn

C 0357207