

ATTESTATION OF CONFORMITY



Number: 2130181.01AOC

Issued to: Delixi Electric Ltd.
Delixi High-tech Industrial park, Liushi Town
325604, Wenzhou, Zhejiang Province, China

For the product: circuit-breaker for overcurrent protection

Trade name: DELIXI ELECTRIC

Type/Model: CDB6s

Ratings: 1, 2, 3, 4, 5, 6, 8, 10, 13, 15, 16, 20, 25, 32, 40, 50 and 63 A; 230/400 Vac for 1-pole; 400 Vac for 2-, 3- and 4-pole, Characteristic B, C, D; see annex for further ratings.

Manufactured by: Delixi Electric (Ningbo) Co., Ltd.
No.1958 Jiangnan Road, Hi-Tech Industrial Development Zone, Ningbo
Zhejiang 315040, China

Requirements: EN 60898-1:2003 + A1:2004 + A11:2005 + A12:2008

This Attestation is granted on account of an examination by KEMA, the results of which are laid down in a confidential file no 3300962.50.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

Arnhem, November 9, 2009

KEMA Quality B.V.

F.S. Strikwerda

Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Ratings:

rated current (In)	:	1, 2, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50 and 63 A
rated voltage (Un)	:	230/400 Vac for 1-pole 400 Vac for 2-, 3- and 4-pole
number of poles	:	1 pole, 2 pole, 3 pole, 4 pole
range of instantaneous tripping overcurrent	:	B, C, D
rated short-circuit capacity (Icn)	:	4500 A for D-type and for B- and C-type with rated current 50 A and 63 A. 6000 A for B- and C type with rated current 1 A - 40 A
rated service short-circuit capacity (Ics)	:	Ics = Icn
energy limiting class	:	1
safety distance "a" grid	:	50 mm
ambient temperature	:	30 °C
method of mounting	:	flush type, for mounting on rail
degree of protection against moisture	:	IP20
connection	:	screw type terminals