



中国国家强制性产品认证证书

证书编号: 2014010307717456

委托人名称、地址

德力西电气有限公司
浙江省乐清市柳市镇德力西高科技工业园区

生产者(制造商)名称、地址

德力西电气有限公司
浙江省乐清市柳市镇德力西高科技工业园区

生产企业名称、地址

德力西电气(芜湖)有限公司
安徽省芜湖市芜湖机械工业园

产品名称和系列、规格、型号

小型断路器

DZ47P Ue: AC230V; In: 6A、10A、16A、20A、25A、32A、40A; C型、D型特性;
Icn=Ics: 4.5kA; 1P+N(带一个保护极, N极可开闭)

产品标准和技术要求

GB 10963.1-2005

上述产品符合强制性产品认证实施规则
CNCA-01C-012:2007的要求,特发此证。

发证日期: 2014年08月26日

有效期至: 2019年08月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0972962



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307717456

NAME AND ADDRESS OF THE APPLICANT

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang
Province, China

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang
Province, China

NAME AND ADDRESS OF THE FACTORY

DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu city, Anhui Province, China 241100

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker
DZ47P Ue: AC230V; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A; Type C, D;
Icn=Ics: 4.5kA; 1P+N(With One Overcurrent Protective Pole, Switched N)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-012:2007).

Date of issue: Aug.26,2014 Date of expiry: Aug.26,2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 0972962