



中国国家强制性产品认证证书

证书编号: 2003010303078974

委托人名称、地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产者(制造商)名称、地址

德力西集团有限公司
浙江省乐清市柳市镇柳青路1号(德力西大厦)

生产企业名称、地址

德力西集团有限公司
浙江省乐清市柳市镇电器城3单元

产品名称和系列、规格、型号

继电器

XJ3-2、XJ3-G、XJ3-5、XJ3-D
Ith:5A:Ue/Ie:AC380V/0.95A, AC240V/1.5A, AC120V/3A; 使用类别:AC-15

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求,特发此证。

发证日期: 2015年05月20日

有效期至: 2020年05月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2003年08月19日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1145651



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010303078974

NAME AND ADDRESS OF THE APPLICANT

DELIXI Group Co., Ltd.
Delixi Building, No. 1 Liuqing Road, Liushi Town, Yueqing, Zhejiang,
P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI Group Co., Ltd.
Delixi Building, No. 1 Liuqing Road, Liushi Town, Yueqing, Zhejiang,
P. R. China

NAME AND ADDRESS OF THE FACTORY

DELIXI Group Co., Ltd.
No. 3 Units Electrical Appliance City, Liushi Town, Yueqing City,
Zhejiang Province, P. R. China.

NAME, MODEL AND SPECIFICATION

Relay

XJ3-2, XJ3-G, XJ3-5, XJ3-D
Ith:5A:Ue/Ie:AC380V/0.95A, AC240V/1.5A, AC120V/3A; Utilization Category: AC-15

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: May. 20, 2015 Date of expiry: May. 20, 2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug. 19, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

Q 1145651