



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20012244736

NAME AND ADDRESS OF THE APPLICANT

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604, P.R.China

NAME AND ADDRESS OF THE FACTORY

DELIXI ELECTRIC LTD (V010114)

Delixi High Tech Industrial park, Liushi Town, Wenzhou, Zhejiang Province, PRC

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-Breaker

DZ47L1E; Uimp: 4kV; Ui: 500V; Ue: AC230V (2P)、AC400V (4P); In: 10A、16A、20A、25A、32A、40A、63A;
IΔ n: 30mA/AC; Electronic Residual Current Tripping Unit ; IΔ m: 500A(In: 10A~40A)、630A(In: 63A); Im: 500A(In:
10A~40A)、630A(In: 63A); Inc: 6000A; IΔ c: 6000A; Poles: 2P、4P;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16916.1-2014, GB/T16916.22-2008

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Apr.27,2020

Valid until: Apr.27,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>