

# 强制性认证产品符合性自我声明



自我声明编号: 2020980307000674

德力西电气有限公司(生产者) 确知知晓《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求, 对本声明承担全部法律责任。

德力西电气有限公司(生产者) 声明以下产品已按照《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求进行检测, 符合相关标准要求; 自本声明签署之日起, 生产和销售的产品持续符合以下标准与实施规则的要求; 保存本声明涉及的技术文档至少10年; 正确使用强制性产品认证标志; 如产品或其符合性信息发生变更, 将及时更新技术文档并报送产品变更信息。

生产者名称: 德力西电气有限公司  
生产者地址: 浙江省温州市乐清市柳市镇德力西高科技工业园区  
依据的强制性产品认证规则: CNCA-C03-02:2014 低压元器件  
产品名称: 万能式断路器  
产品系列、型号、规格: CDW9-3200H, CDW9-3200H/4; 参数详见附件  
依据的标准: GB/T 14048.2-2008  
生产企业名称: 德力西电气有限公司  
生产企业地址: 浙江省乐清市柳市镇德力西高科技工业园区

联系人: 郭建权  
电话: 0577-61778125  
电子邮箱: jianquan.guo@delixi-electric.com  
指定签字人:

自我声明时间: 2020-07-01

自我声明地点: 温州

生产者签章:



注: 有关本声明信息真伪可登录全国认证认可信息公共服务平台 (cx.cnca.cn) 或扫描右上角二维码查询。

# 强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307000674

产品系列、型号、规格(附件):

CDW9-3200H, CDW9-3200H/4;  
Ui: 1000V;  
Uimp: 12kV;  
Ue: AC220V/230V/240V, AC380V/400V/415V,  
AC440V/480V/500V/525V/550V, AC660V/690V;  
In: 2000A, 2500A, 3200A;  
ETU:  
Ics: 85kA (AC220V/230V/240V, AC380V/400V/415V),  
70kA (AC440V/480V/500V/525V/550V, AC660V/690V);  
Icu: 100kA (AC220V/230V/240V, AC380V/400V/415V),  
70kA (AC440V/480V/500V/525V/550V, AC660V/690V);  
Icw: 85kA/1s (AC220V/230V/240V, AC380V/400V/415V),  
70kA/1s (AC440V/480V/500V/525V/550V, AC660V/690V);  
Utilization Category: B;  
Poles: 3P, 4P; Suitable for isolation: 50/60Hz;  
Attached Auxiliary Contacts (4NO/4NC): 1th: 6A;  
AC-15: Ue/le: AC400V/0.9A, AC230V/1.5A;  
DC-13: Ue/le: DC220V/0.27A, DC110V/0.55A;  
Electronic accessories in accordance with appendix N:  
Shunt release MX: AC220/230V 50/60Hz, AC380/400V 50/60Hz, DC110V, DC220V;  
Undervoltage release MN: AC220/230V 50/60Hz, AC380/400V 50/60Hz;

联系人: 郭建权  
电话: 0577-61778125  
电子邮箱: jianquan.guo@delixi-electric.com  
指定签字人:

自我声明时间: 2020-07-01

自我声明地点: 温州

生产者签章:



注: 有关本声明信息真伪可登录全国认证认可信息公共服务平台 (cx.cnca.cn) 或扫描右上角二维码查询。

# 强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307000674

产品系列、型号、规格(附件):

CDW9-3200H, CDW9-3200H/4;  
额定绝缘电压(Ui): 1000V;  
额定冲击耐受电压(Uimp): 12kV;  
额定工作电压(Ue): AC220V/230V/240V, AC380V/400V/415V,  
AC440V/480V/500V/525V/550V, AC660V/690V;  
额定电流(In): 2000A, 2500A, 3200A;  
过电流脱扣器型式: 电子式;  
Ics: 85kA (AC220V/230V/240V, AC380V/400V/415V),  
70kA (AC440V/480V/500V/525V/550V, AC660V/690V);  
Icu: 100kA (AC220V/230V/240V, AC380V/400V/415V),  
70kA (AC440V/480V/500V/525V/550V, AC660V/690V);  
Icw: 85kA/1s (AC220V/230V/240V, AC380V/400V/415V),  
70kA/1s (AC440V/480V/500V/525V/550V, AC660V/690V);  
使用类别: B;  
极数: 3P, 4P; 适用于隔离; 额定频率: 50/60Hz;  
使用的辅助触头 (4NO4NC): Ith: 6A;  
AC-15: Ue/le: AC400V/0.9A, AC230V/1.5A;  
DC-13: Ue/le: DC220V/0.27A, DC110V/0.55A;  
符合附录 N 的电子附件:  
分励脱扣器 MX: AC220/230V 50/60Hz, AC380/400V 50/60Hz, DC110V, DC220V;  
欠电压脱扣器 MN: AC220/230V 50/60Hz, AC380/400V 50/60Hz;

联系人:  
电话:  
电子邮箱:  
指定签字人:

郭建权  
0577-61778125  
jianquan.guo@delixi-electric.com

自我声明时间: 2020-07-01  
自我声明地点: 温州

生产者签章:



注: 有关本声明信息真伪可登录全国认证认可信息公共服务平台 (cx.cnca.cn) 或扫描右上角二维码查询。