



产品认证证书

证书编号: CQC2003010304074285

申请人名称及地址

浙江德力西电器有限公司
浙江省乐清市柳市镇翔金垟村

制造商名称及地址

浙江德力西电器有限公司
浙江省乐清市柳市镇翔金垟村

生产企业名称及地址

浙江德力西电器有限公司 (V054962)
浙江省乐清市柳市镇腾飞路 28 号

产品名称和系列、规格、型号

自耦减压起动控制柜

JJ1B-11kW, JJ1B-15kW, JJ1B-18.5kW, JJ1B-22kW, JJ1B-30kW, JJ1B-40kW, JJ1B-45kW, JJ1B-55kW, JJ1B-75kW, JJ1B-100kW, JJ1B-115kW, JJ1B-135kW, JJ1B-160kW, JJ1B-190kW; Ui: 660V; Uimp: 6kV; Ith: 22A(JJ1B-11kW), 29A(JJ1B-15kW), 36A(JJ1B-18.5kW), 42A(JJ1B-22kW), 57A(JJ1B-30kW), 0A(JJ1B-40kW), 84A(JJ1B-45kW), 103A(JJ1B-55kW), 140A(JJ1B-75kW), 184A(JJ1B-100kW), 219A(JJ1B-115kW), 252A(JJ1B-135kW), 300A(JJ1B-160kW), 351A(JJ1B-190kW); AC-3; Ue: AC380V; Ie: 22A(JJ1B-11kW), 29A(JJ1B-15kW), 36A(JJ1B-18.5kW), 42A(JJ1B-22kW), 57A(JJ1B-30kW), 80A(JJ1B-40kW), 84A(JJ1B-45kW), 103A(JJ1B-55kW), 140A(JJ1B-75kW), 184A(JJ1B-100kW), 219A(JJ1B-115kW), 252A(JJ1B-135kW), 300A(JJ1B-160kW), 351A(JJ1B-190kW); Pe: 11kW(JJ1B-11kW), 15kW(JJ1B-15kW), 18.5kW(JJ1B-18.5kW), 22kW(JJ1B-22kW), 30kW(JJ1B-30kW), 40kW(JJ1B-40kW), 45kW(JJ1B-45kW), 55kW(JJ1B-55kW), 75kW(JJ1B-75kW), 100kW(JJ1B-100kW), 115kW(JJ1B-115kW), 135kW(JJ1B-135kW), 160kW(JJ1B-160kW), 190kW(JJ1B-190kW); 脱扣级别: 10A; 3P; IP30

产品标准和技术要求

GB/T14048. 4-2010

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 09 月 02 日 有效期至: 2022 年 09 月 05 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0347723



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2003010304074285

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Delixi Electrical Co., Ltd.
Xiangjinyang Village, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Delixi Electrical Co., Ltd.
Xiangjinyang Village, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Delixi Electrical Co., Ltd. (V054962)
No.28 Tengfei Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Coupling Decompression Starting Control Cabinet

JJ1B-11kW, JJ1B-15kW, JJ1B-18.5kW, JJ1B-22kW, JJ1B-30kW, JJ1B-40kW, JJ1B-45kW, JJ1B-55kW, JJ1B-75kW, JJ1B-100kW, JJ1B-115kW, JJ1B-135kW, JJ1B-160kW, JJ1B-190kW; Ui: 660V; Uimp: 6kV; Ith: 22A(JJ1B-11kW), 29A(JJ1B-15kW), 36A(JJ1B-18.5kW), 42A(JJ1B-22kW), 57A(JJ1B-30kW), 80A(JJ1B-40kW), 84A(JJ1B-45kW), 103A(JJ1B-55kW), 140A(JJ1B-75kW), 184A(JJ1B-100kW), 219A(JJ1B-115kW), 252A(JJ1B-135kW), 300A(JJ1B-160kW), 351A(JJ1B-190kW); AC-3; Ue: AC380V; Ie: 22A(JJ1B-11kW), 29A(JJ1B-15kW), 36A(JJ1B-18.5kW), 42A(JJ1B-22kW), 57A(JJ1B-30kW), 80A(JJ1B-40kW), 84A(JJ1B-45kW), 103A(JJ1B-55kW), 140A(JJ1B-75kW), 184A(JJ1B-100kW), 219A(JJ1B-115kW), 252A(JJ1B-135kW), 300A(JJ1B-160kW), 351A(JJ1B-190kW); Pe: 11kW(JJ1B-11kW), 15kW(JJ1B-15kW), 18.5kW(JJ1B-18.5kW), 22kW(JJ1B-22kW), 30kW(JJ1B-30kW), 40kW(JJ1B-40kW), 45kW(JJ1B-45kW), 55kW(JJ1B-55kW), 75kW(JJ1B-75kW), 100kW(JJ1B-100kW), 115kW(JJ1B-115kW), 135kW(JJ1B-135kW), 160kW(JJ1B-160kW), 190kW(JJ1B-190kW); Trip Class: 10A; 3P; IP30

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.02,2020

Valid until: Sep.05,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0347723