



中国认可
国际互认
检测
TESTING
CNAS L1145

国家强制性产品认证

试验报告

新申请 变更 监督 复审 其他:

申请编号: A2020CCC0304-3510925

(任务编号)

产品名称: 交流接触器

型 号: CJX2s-09(N), CJX2s-12(N), CJX2s-18(N),
CJX2sK-09(N), CJX2sK-12(N), CJX2sK-18(N),
CJX2v-09(N), CJX2v-12(N), CJX2v-18(N),
CJX2H-09(N), CJX2H-12(N), CJX2H-18(N)





检测机构: 上海电器设备检测所有限公司



<p>样品名称: 交流接触器 型 号: CJX2s-09(N), CJX2s-12(N), CJX2s-18(N), CJX2sK-09(N), CJX2sK-12(N), CJX2sK-18(N), CJX2v-09(N), CJX2v-12(N), CJX2v-18(N), CJX2H-09(N), CJX2H-12(N), CJX2H-18(N)</p> <p>商 标: DELIXI ELECTRIC 样品数量: 22 台 样品来源: 工厂送样</p> <p>收样日期: 2020-06-24 完成日期: 2020-08-11</p>	<p>委托人: 德力西电气有限公司 委托人地址: 浙江省乐清市柳市镇德力西高科技工业园区</p> <p>生产者: 德力西电气有限公司 生产者地址: 浙江省乐清市柳市镇德力西高科技工业园区</p> <p>生产企业: 德力西电气有限公司 生产企业地址: 浙江省乐清市柳市镇德力西高科技工业园区</p>
--	---

试验结论: 依据 GB/T 14048.4-2010 检验合格

本申请认证单元所覆盖的产品型号规格及相关情况说明: 见附页 1

<p>主检:  日期: 2020-08-12</p>	 <p>(检测机构名称 盖章) 2020 年 08 月 12 日</p>
<p>审核:  日期: 2020-08-12</p>	
<p>签发:  日期: 2020-08-12</p>	

备注: 见附页 2

附页 1:

CJX2s-09(N), CJX2s-12(N), CJX2s-18(N), CJX2sK-09(N), CJX2sK-12(N),
CJX2sK-18(N), CJX2v-09(N), CJX2v-12(N), CJX2v-18(N), CJX2H-09(N),
CJX2H-12(N), CJX2H-18(N)

Uimp: 6kV;

Ui: 690V;

CJX2s-09(N), CJX2sK-09(N), CJX2v-09(N), CJX2H-09(N)

Ith: 25A;

AC-3: AC220V/230V/9A, AC380V/400V/9A, AC660V/690V/6.6A;

AC-4: AC380V/400V/3.5A, AC660V/690V/1.5A;

CJX2s-12(N), CJX2sK-12(N), CJX2v-12(N), CJX2H-12(N)

Ith: 25A;

AC-3: AC220V/230V/12A, AC380V/400V/12A, AC660V/690V/8.9A;

AC-4: AC380V/400V/5A, AC660V/690V/2A;

CJX2s-18(N), CJX2sK-18(N), CJX2v-18(N), CJX2H-18(N)

Ith: 32A;

AC-3: AC220V/230V/18A, AC380V/400V/18A, AC660V/690V/12A;

AC-4: AC380V/400V/7.7A, AC660V/690V/3.8A;

使用类别: AC-3, AC-4;

Us: AC24V,36V,48V,110V,127V,220V/230V,240V,380V/400V,415V,440V
50Hz, 50/60Hz;

3P;

IP20;

配用的辅助触头 (本体):

Ith: 10A;

1NO, 1NC, 1NO1NC;

AC-15: Ue/Ie: AC220V/1.6A, AC380V/0.95A

DC-13: Ue/Ie: DC220V/0.15A