

产品认证证书

II型自愿认证

证书编号：CQC2019010302182923

发证日期：2021年07月28日

有效期至：2024年05月09日

委托人名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
制造商名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
生产企业名称	德力西集团有限公司
及生产地址	乐清市柳市镇站东路155号
产品名称和系列、规格、型号	熔断器式隔离开关 HR6-800/30、HR6-800/31; Ue:AC400V/690V; Ie:800A(AC400V)、630A(AC690V); Ui:1000V; Uimp:12kV; Ith:800A; 额定限制短路电流:100kA(AC400V)、50kA(AC690V); 使用类别:AC-23B(AC400V)、AC-21B(AC690V); 极数:3P; 辅助回路:1NO1NC; Ith:6A; AC-15; Ue/Ie:AC380V/1A;
产品标准和技术要求	GB/T 14048.3-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求,特发此证。

本证书为变更证书,证书首次颁发日期:2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

陈昕

签发

谢肇煦



中国质量认证中心

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302182923

Valid from: Jul.28,2021

Valid until: May.09,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY DELIXI Group Co., Ltd.
NO.155 Zhandong Road, Liushi Town, Yueqing City

PRODUCT NAME, MODEL AND SPECIFICATION Fuse-switch-disconnector
HR6-800/30、HR6-800/31; Ue : AC400V/690V ; Ie : 800A (AC400V) 、 630A (AC690V) ; Ui : 1000V ; Uimp : 12kV ; Ith : 800A ; Conditional Short-circuit Current : 100kA (AC400V) 、 50kA (AC690V) ; Utilization Category : AC-23B (AC400V) 、 AC-21B (AC690V) ; Poles : 3P ; Attached Auxiliary Contacts : 1NO1NC ; Ith : 6A ; AC-15 ; Ue/Ie : AC380V/1A ;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE