

产品认证证书

II型自愿认证

证书编号: CQC2003010309095687

发证日期: 2021年07月28日

有效期至: 2024年12月23日

委托人名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
制造商名称	德力西集团有限公司
及注册地址	浙江省乐清市柳市镇柳青路1号(德力西大厦,另设分支机构经营场所:乐清市柳市镇站东路155号)
生产企业名称	德力西集团有限公司
及生产地址	乐清市柳市镇站东路155号
产品名称和系列、规格、型号	电动机综合保护器 JD-5,JD-5B,JD-5A,JD-5P,JD-5S: Uimp:6kV;Ui:380V;Ue:AC380V;Ie:JD-5,JD-5B:1~80A,0.5~5A,2~20A,20~80A,1~100A; JD-5A:0.5-5A、2-20A、10-100A;JD-5P:1~4.9A,5~49A,20~79A;JD-5S:1~9.9A,10~99A; 脱扣级别:10A(JD-5,JD-5B,JD-5A,JD-5P);10A,10,20,30(JD-5S);3P;IP40;配用辅助触头(本体):Ith:3A;Uimp:2.5kV;AC-15:Ue/Ie:AC220V/0.47A;1NC(JD-5,JD-5B,JD-5A,JD-5P),1NO(JD-5S)
产品标准和技术要求	GB/T 14048.4-2010
认证模式	型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求,特发此证。

本证书为变更证书,证书首次颁发日期:2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2003010309095687

Valid from: Jul.28,2021

Valid until: Dec.23,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT	DELIXI Group Co., Ltd. (Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	DELIXI Group Co., Ltd. (Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China
NAME AND LOCATION OF THE FACTORY	DELIXI Group Co., Ltd. NO.155 Zhandong Road, Liushi Town, Yueqing City
PRODUCT NAME, MODEL AND SPECIFICATION	Comprehensive Protector for Motors JD-5,JD-5B,JD-5A,JD-5P,JD-5S : Uimp:6kV;Ui:380V;Ue:AC380V;Ie:JD-5,JD-5B:1~80A,0.5~5A,2~20A,20~80A,1~100A;JD-5A:0.5-5A、2-20A、10-100A;JD-5P:1~4.9A,5~49A,20~79A;JD-5S:1~9.9A,10~99A;Trip Class:10A(JD-5,JD-5B,JD-5A,JD-5P);10A,10,20,30(JD-5S);3P;IP40 ; Attached Auxiliary Contacts:Ith:3A;Uimp:2.5kV;AC-15:Ue/Ie:AC220V/0.47A;1NC(JD-5,JD-5B,JD-5A,JD-5P),1NO(JD-5S)
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2010
TYPE OF CERTIFICATION SCHEMES	Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE