

产品认证证书

II型自愿认证

证书编号: CQC2005010309149414

发证日期: 2021 年 07 月 28 日

有效期至: 2031 年 07 月 28 日

委托人名称	浙江德力西电器有限公司
及注册地址	浙江省乐清市柳市镇站东路 155 号
制造商名称	浙江德力西电器有限公司
及注册地址	浙江省乐清市柳市镇站东路 155 号
生产企业名称	浙江德力西电器有限公司
及生产地址	浙江省乐清市柳市镇站东路 155 号
产品名称和系列、 规格、型号	自耦减压起动箱 XJD1-225kW, XJD1-260kW, XJD1-300kW;Ui: 660V;Uimp:6kV;Ith:407A(XJD1-225kW),469A(XJD1-260kW),537A(XJD1-300kW);AC- 3;Ue: AC380V;Ie: 407A(XJD1-225kW),469A(XJD1-260kW),537A(XJD1-300kW);Pe: 225kW(XJD1-225kW),260kW(XJD1-260kW),300kW(XJD1-300kW);脱扣级别: 10A;3P;IP10
产品标准和技术要求	GB/T 14048.4-2010
认证模式	型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 09 月 02 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2005010309149414

Valid from: Jul.28,2021

Valid until: Jul.28,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Delixi Electrical Co.,Ltd.
NO.155, ZhanDong Road, Liushi Town, Yueqing City, Zhejiang Province , P.R. China.

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Delixi Electrical Co.,Ltd.
NO.155, ZhanDong Road, Liushi Town, Yueqing City, Zhejiang Province , P.R. China.

NAME AND LOCATION OF THE FACTORY Zhejiang Delixi Electrical Co.,Ltd.
NO.155, ZhanDong Road, Liushi Town, Yueqing City, Zhejiang Province , P.R. China.

PRODUCT NAME, MODEL AND SPECIFICATION Coupling Decompression Starting Control Cabinet
XJD1-225kW, XJD1-260kW, XJD1-300kW;Ui:
660V;Uimp:6kV;Ith:407A(XJD1-225kW),469A(XJD1-260kW),537A(XJD1-300kW);AC-3;Ue:
AC380V;Ie: 407A(XJD1-225kW),469A(XJD1-260kW),537A(XJD1-300kW);Pe:
225kW(XJD1-225kW),260kW(XJD1-260kW),300kW(XJD1-300kW);Trip Class : 10A;3P;IP10

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2010

TYPE OF CERTIFICATION SCHEMES Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE