



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006478

| | |
|-----------------------|--|
| Product | Solid state relay |
| Applicant | DELIXI Group Co., Ltd. (Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang Province, P.R.China |
| Type/Model | CDG1-1DA, CDG1-1AA, CDG1-1DD |
| Technical data | Uimp:2.5kV; Ui:500V; Ith:10A,15A,20A,25A,30A,40A,60A,75A,80A,100A,120A(CDG1-1 DA,CDG1-1AA), 10A,25A,40A,60A,80A(CDG1-1DD); AC-12:Ue:AC24-480V,Ie:10A,15A,20A,25A,30A,40A,60A,75A,80A ,100A,120A(CDG1-1DA,CDG1-1AA); DC-12:Ue:DC12-220V,Ie:10A,25A,40A,60A,80A(CDG1-1DD); Us:DC3-32V(DC input, AC output)(CDG1-1DA), AC80-280V(AC input, AC output)(CDG1-1AA), DC3-32V(DC input, DC output)(CDG1-1DD) |

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-19D0028-S, the submitted sample(s) of the above item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Oct.10,2019

Valid until: Oct.10,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
 Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>