



Ref. Certif. No.

SE-52871IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product
Produit

Moulded case circuit-breaker

Name and address of the applicant
Nom et adresse du demandeurDelixi Electric Ltd.
Delixi high-tech. industry park, Liushi Town, Yueqing,
Zhejiang 325604, CHINAName and address of the manufacturer
Nom et adresse du fabricant

Same as applicant

Name and address of the factory
Nom et adresse de l'usine

Same as applicant

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales $U_e = 240V \sim (1\text{-pole}), 415V \sim (2\text{-}, 3\text{-}, 4\text{-poles})$
 $I_n = 63, 80, 100, 125A$
 $I_{cu} = 10000A, I_{cs} = 7500A$, See also page 2Trademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De type

CDB2-125

Additional information (if necessary)
Les informations complémentaires (si nécessaire)

See page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-2:2006

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

715728-1, -2, -3, -4

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Intertek

ETL SEMKO

Signature:

Ulf Hedlund

Date: 19 December 2007



Ref. Certif. No.

SE-52871

Additional information (if necessary)
Information complémentaire (si nécessaire)

Instantaneous tripping: C-type(8,5I_n), D-type(12I_n)

Date: 19 December 2007

Signature: