

CB TEST CERTIFICATE

Ref. Certificate No.

NL-11714-B2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:

KEMA Quality B.V.

Product:

RCCB

Applicant:

Delixi Electric Ltd.

Delixi High Tech Industrial China

Park, Liushi Town, 325604 Wenzhou,

ZHEJIANG PROVINCE

Manufacturer:

Factory:

Zhejiang DEHUI

DELIXI BUILDING

China

Electric Co., Ltd.

XIANGJINYANG, Liushi,

Wenzhou, Zhejiang DELIXI BUILDING

Zhejiang DEHUI Electric Co., Ltd.

XIANGJINYANG, Liushi,

China

Wenzhou, Zhejiang

Rating and principal

characteristics:

2P & 4P, 10, 16, 20, 25A / 10, 30, 100, 300,

500mA

2P & 4P, 32, 40, 63, 80, 100A / 30, 100,

300, 500mA

A type or AC type, without time-delay

230 / 400 Vac

Trade mark (if any):

DELIXI ELECTRIC

Model/Type reference:

CDL7-100

Additional information:

based on CB NL-11714, issued 2007-01-11

Sample of product tested to be in conformity with IEC: 61008-1(ed.2);am1;am2

Test Report Ref. No:

S0607075.50 / W0804036.50

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V. Utrechtseweg 310 P.O. Box 5185 6802 ED Arnhem The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2008-12-22